

GOVERNMENT OF TRIPURA
SUB-DIVISION LEVEL WATER TESTING LABORATORY
Drinking Water & Sanitation, Jirania, West Tripura

TEST REPORT

Name & Address of the customer:


Birendra nagar H.S
school, Jirania W Tripura.
SDTW

Date of Receipt of Sample : 20.8.26
Date of Start of Performance : 20.8.26
Date of End of Performance : 21.8.26
Date of Issue of Report : 21.8.26

Analysis of Result

Sl. No.	Name of Test / Parameters	Permissible Limit (BIS 10500:2012)	Method of Testing	Result
1	pH value at 25.0 °C	6.5-8.5	Instrumental Method	7.0
2	Turbidity in NTU	5NTU	Instrumental Method	0.26
3	Total Dissolved Solid in mg /l.	2000	APHA 24 th Edition 2540 C	149
4	Iron (as Fe) in mg/l	1.0	UV-Visible Spectrophotometer	0.136
5	Total Coliform Bacteria (E.coli)	No Relaxation	MPN	0.0

Analyzed By:


L. Debbarma
(Senior Research Assistant)
PWD(DWS) Sub-Division Level Laboratory
Jirania Tripura (West)

Reviewed & Authorized by:


(Er. S. Debbarma)
Sub-Divisional Officer
PWD(DWS) Sub-Division Jirania
Jirania Tripura (West)

**OFFICE OF THE
EXECUTIVE OFFICER
JIRANIA NAGAR PANCHAYAT
JIRANIA, WEST TRIPURA**

F.No.6 (2)/JRN-NP/DW/SBM/2026-27/ 2678-2680

Dated, 13 /08/2026

HYGIENIC SANITATION CERTIFICATE

To Whom It May Concern

Certified that the Sanitation system arrangement of Birendranagar H.S. School, Jirania, West Tripura is being maintained properly, hygienically and safely. As such, the Jirania Nagar Panchayat has no objection to run the Birendranagar H.S. School under the following terms and conditions.

1. That the Certificate is valid only for 1(One) year from the date of issue (i.e. from 13.08.2026).
2. That in case any complaints regarding Nuisance/ Health hazard/ Sanitary defects are noticed, the validity of the certificate may be called off at any time even before the date of expiry.
3. That the proper methods and manner of Hygiene disinfection must be ensured.
4. That the admissible process as specified in relation to Solid Waste Management Rules, 2026 (4 way segregated manner) like Bio-degradable, Non bio-degradable, Hazardous (Special care waste) & Sanitary waste is to be followed strictly.
5. That the School authority should have to follow the Office to Office garbage collection process introduced by the Jirania Nagar Panchayat in regular manner.

 13.08.2026
**Dy. Executive Officer
Jirania Nagar Panchayat
Jirania, West Tripura**

Copy to:

1. The Executive Officer, Jirania NP for kind information.

Copy also forwarded to:

1. The Honb'le Chairperson, Jirania N.P for kind information.
2. The Honb'le Vice-Chairperson, Jirania N.P for kind information.

 13.08.2026
**Dy. Executive Officer
Jirania Nagar Panchayat
Jirania, West Tripura**